TEST LAB INC.
GEOTECHNICAL & MATERIALS
ENGINEERING, TESTING & INSPECTION
P O BOX 15732 - TAMPA, FLORIDA 33684 - 813/872-7821

SIEVE ANALYSIS

PROJECT: Product Check **PROJECT NO:** TL-8047

CLIENT: Kimmins Contracting Corporation **DATE:** July 7, 2010

SAMPLE LOCATION: 53rd Street Processing Facility – Stockpile

SAMPLE DESCRIPTION: No. 4 Aggregate (Crushed Concrete)

Sieve Number	Percent Passing	No. 4 Aggregate ASTM C 33
2"	100	100
1½"	100	90-100
1"	77	20-55
¾"	16	0-15
½"	6	---
⅜"	6	0-5

FINENESS MODULUS: 7.79

DATE SAMPLED: 6/30/10

DATE TESTED: 7/1/10

REPORTS TO:
Kimmins Contracting Corporation
Attn: Eric Wilhelm (2)

ewilhelm@kimmins.com

TEST LAB, INC.

dtl/svs 282