

## Product Comparison Report

Period: 01/14/2011

Plant	FDOT # 16-564	FDOT # 16-564
	1037291-Underdrain Sand	1225644-Underdrain Sand P2 Type V
Sieve/Test	Average	Average
3/8" (9.5mm)	100.0	100.0
#4 (4.75mm)	100.0	100.0
#8 (2.36mm)	99.9	99.8
#16 (1.18mm)	93.2	91.0
#30 (0.6mm)	55.3	44.3
#50 (0.3mm)	20.9	12.2
#100 (0.15mm)	2.9	1.6
#200 (75um)	0.10	0.10
PAN (0um)	0.00	0.00
Cu	3.26	2.87
ES (D10)	0.20	0.27
#200 (75um)	0.1	0.1
Color	1	1
Total Moisture	3.7	2.9
FM	2.28	2.51
Permeability	167	173